

Product: Single phase and three phase low voltage squirrel cage induction motors

Type: 5AZC 63-112, 5AZCD 63-112, 5AZ 56-160, 7AZ 100-315, 8AZ 132-315, 5AT 71-112, 5AT 132-315, 5AZS 63-112

Manufacturer: KONČAR-MES d.d.
Fallerovo šetalište 22, Zagreb

Certification ordered by: KONČAR-MES d.d.
Fallerovo šetalište 22, Zagreb

Number of contract: Application for certification dated 22.09.2015.


Specification: EMC Directive 2004/108/EC

Test method: EN 61000-6-1:2007
EN 61000-6-2:2008
EN 61000-6-3:2007+A1:2011
EN 61000-6-4:2008+A11:2011
EN 61000-3-2:2014
EN 61000-3-3:2013
EN 61000-3-11:2000
EN 61000-3-12:2011
EN 60034-1:2010+AC:2010

Date of issue: 29.09.2015.

Conclusion: According to EMC Directive 2004/108/EC and guide of implementing for the EMC Directive 2004/108/EC (8th February 2010), clause 11.4, induction motors are declared as passive components regarding EMC requirements and fulfil the essential requirements of EMC directive without testing.

Evaluation realised by: Saša Gros, B.Sc.E.E



KONČAR - Institut za
elektrotehniku d. d.
ZAGREB

The test report shall not be reproduced in full without the written approval of Končar – Electrical Engineering Institute, Inc.

Address: KONČAR – Electrical Engineering Institute, Inc.
pp 202, HR-10002 ZAGREB, Fallerovo šetalište 22

Phone: 385 (0)1 3667-315
385 (0)1 3666-351
Fax: 385 (0)1 3667-309

e-mail: info-iet@koncar-institut.hr

<http://www.koncar-institut.hr>